




Certificate of Compatibility

We are pleased to confirm that



Kentec Electronics Ltd

Syncro AS - Analogue Addressable Fire Alarm Control Panel

Type - EN54
Software Version - 5.23 UK

has been tested and approved for use with
XPlorer[®], XP95[®] and Discovery[®] digital communications protocols
and devices in accordance with Apollo test schedule TSP 01


Observations are listed in Appendix A attached


Project no: TSE 243

Certificate no: 132

Issued on: 23rd January 2009

Signed:


S. Flavell, Technical Sales Supervisor


P. Smith, Marketing Director



Certificate of Compatibility – Appendix A

The following XP95 feature is not supported:

Group Address

The following Discovery feature is not supported:

Drift Compensation Value

(viewable)

User Bytes (E² location 11)

User Bytes (E² location 12)

User Bytes (E² location 13)

User Bytes (E² location 14)

Month of Manufacture (viewable)

Approval Code

Conventional Alarm Facility

Project no: TSE 243

Certificate no: 131 - 133