


STANDARD BELL BOOSTERS VERSIONS:

K17402 03 2-way Bell Booster = SB.03 x1 no. & 5.25A PSU.

K17404 03 4-way Bell Booster = SB.03 x1 no. + SB.01 x1 & 5.25A PSU.

K17406 03 6-way Bell Booster = SB.03 x1 no. + SB.02 x2 & 5.25A PSU.

If more than 2 no. SB-03/SB-02 PCB's are to be fitted then 24v DC power must be wired to each additional SB.02 PCB.



REV	REVISION	REL/C NOTE	DATE
A	RELEASE	Pre '93	18/06/1991
01	DRAWN ON COMPUTER		28/03/2001
02	CHANGE	C8350	21/12/2007
03	CHANGE	C10337	03/01/2012

TITLE BELL/SOUNDER BOOSTER UNIT ~ Internal Circuit Wiring			
CLIENT			
DATE DRAWN	28/03/2001	DRAWN	Ian D.
W/O No.		PSU/BATT	as above
		CHECKED BY	
		DRG No.	K.929-02